Reproduced from the holdings of the National Archives
Pacific Southwest Region

SENT

PRESIDENT	
EXEC VICE PRES	
V PRES & GEN MGR	
CH FISCAL OFFCR	
ASST GEN MGR	I
OPER-CONST	I
INDUS RELATIONS	
PROCUREMENT	
ESTIMATING	
OFFICE MANAGER	
DIR OF ENGRNG	
CH DESIGN ENGR	
CH PROJECT ENGR	I
PROJECT ENGR	I
SALES DIVISION	
ACCOUNTING	
SECURITY	

HN-1

RR UHPJ

SECURITY INFORMATION
RESTRICTED

DE LA254/UWFJAX 50

R 181655Z

AEC GR138

This material contains information affecting the national defense of the United States within the meaning of the espionage laws, Title 18, U.S.C., Secs. 793 and 794, the transmission or revelation of which in any manner to an unauthorized person is prohibited by law."

PAREN RESTRICTED PAREN SECURITY INFORMATION PD FROM HOW NAN LOSA PASS TO HOW NAN ENIWETOK PD HOW NAN EIGHT EIGHT SEVEN NINE PD BOETTCHER FROM DAVE NARVER JR PD REURMSG THREE TWO SIX SIX PD THICKNESS OF FIRST FLOOR WALL SHOWN ON DWG SIX THREE TWO FIVE CMM RIGHT HAND SIDE OF SECTION DOG SHOULD BE SIX FEET PD STEEL IN EACH FACE SHOULD BE NR NINE AT ONE ZERO VERTICAL AND NR EIGHT AT ONE ZERO HORIZONTAL PARA SIMULTANEOUS POURING OF LIMONITE FRONT WALL AND REGULAR CONCRETE SIDE WALLS TO ELIMINATE COLD JOINT IS PERMITTED CMM PROVIDED THAT THE THICKNESS OF THE LIMONITE SPECIFIED ON THE DWG IS NOT REDUCED BY DIFFUSION OF THE REGULAR CONCRETE POUR INTO THE LIMONITE PARA DWG SIX TWO SIX ONE NO LONGER APPLIES TO STATION TWO THREE ZERO ZERO PD

18/1718Z

DEPARTMENT OF ENERGY
SINGLE REVIEW AUTHORITY
REVIEWER (ADD)
NAME
DATE