

~~RESTRICTED~~

*Elmer General*

S. P. Howell

804

405914

R

David L. Harver, Jr. POL By Pass - Elmer

January 20, 1953

*DN*  
*HR*

The enclosed is a partial reproduction of P.S. 693 (As-Built).

According to C. W. Kelley, you could pump diesel and gasoline at the same time. If this is so, how'd you prevent interflow through the flanged coupling, immediately beyond the first incoming valves, that connects the two incoming pipes.

David L. Harver, Jr.  
Chief Project Engineer

DLHjr:mas  
Enc. (1)

cc: JS Chrono  
Constr.-Oper. Div.  
Project Engineering File ✓  
Engineering File  
616 Mail Room (2)

BEST COPY AVAILABLE

REPOSITORY NATIONAL ARCHIVES  
PACIFIC SOUTHWEST REGION  
COLLECTION RG 326 ATOMIC ENERGY COMMISSION  
BOX No. 199624 (#608) A16334 326-65VD170  
ELMER GENERAL  
FOLDER 308 834 PROJECT ENGINEERING FILE

"This material contains information affecting the national defense of the United States within the meaning of the espionage laws, Title 18, U.S.C., Secs. 793 and 794, the transmission or revelation of which in any manner to an unauthorized person is prohibited by law."

*POL*

DEPARTMENT OF ENERGY DECLASSIFICATION REVIEW	
DATE REVIEW AUTHORIZED BY: <i>7/23/94</i>	DETERMINATION (CIRCLE NUMBER(S))
REVIEWER (DDP): <i>[Signature]</i>	1. CLASSIFICATION RETAINED
NAME: <i>[Signature]</i>	2. CLASSIFICATION CHANGED TO:
DATE: <i>7/23/94</i>	3. CONTAINS NO DOE CLASSIFIED INFO
	4. COORDINATE WITH:
	5. CLASSIFICATION CANCELLED
	6. CLASSIFIED INFO BRACKETED

~~SECURITY INFORMATION~~  
~~RESTRICTED~~