

DAVID NARVER JR FROM CORAY PD QUOTE EDWARDS FROM HARBERT PD IT IS REQUESTED THAT AUTHORIZATION BE GIVEN TO SUBSTITUTE NUMBER ONE ZERO BAR AT FOUR AND EIGHT INCHES FOR NUMBER ONE ONE BARS AT FIVE AND ONE ZERO INCHES CMM STATION ONE THREE FOUR ONE PD IT IS ALSO REQUESTED TO SUBSTITUTE NUMBER ONE ZERO BARS AT FIVE AND NINE AND ONE HALF INCHES-FOR NUMBER ONE ONE AT SIX AND ONE TWO INCHES CMM STATION ONE TWO ONE ZERO PD IT IS ALSO REQUESTED TO SUBSTITUTE NUMBER ONE ZERO AT FOUR INCHES FOR NUMBER ONE ONE AT FIVE INCHES CMM STATION ONE TWO ZERO ZERO

RESTRICTED

PD IS URGENT THAT ACTION BE TAKEN UPON THIS IMMEDIATELY AS STEEL WORK WILL BE HELD UP PD UNQUOTE PLEASE ADVISE PRIORITY TELETYPE ほー モミノウルちつフ