Reproduced from the holdings of the National Archives
Pacific Sou

HN-08

RR UHPJ

~~SECURITY INFORMATION~~

DE LA254/UWFJAX 36

R 092113Z

AEC GF91

BEST COPY AVAILABLE

PAREN ~~RESTRICTED~~ PAREN ~~SECURITY INFORMATION~~ PD HOW NAN LOSA PASS TO HOW NAN ENIWETOK PD HOW NAN NINE ONE SIX FIVE PD BOETTCHER FROM DAVID NARVER JR PD REURMSG THREE SEVEN FOUR ZERO PD PRELIMINARY DRAWING THREE TWO NINE SIX DATED AUGUST TWO FIVE SATISFACTORY WITH FOLLOWING REVISIONS CLN ONE PAREN RUNS FROM GENERATORS TO PANELS ARE THREE INCHES INSTEAD OF TWO INCHES PD TWO PAREN CIRCUIT SEVEN IS ONE INCH INSTEAD OF THREE SLASH FOUR INCHES PD MECHANICAL DRAWINGS BEING ISSUED TODAY WHICH SHOW HOLES IN EQUIPMENT ROOM FLOOR

09/2120Z

DEPARTMENT OF ENERGY
SINGLE REVIEW
REVIEWER (AD)
NAME
DATE