

COPY

COPY

COPY

Reproduced from the holdings of the National Archives

HOIMES & HARVEY, INC. *Pacific Southwest Region*

ENGINEERING CONSTRUCTION

R

TO: R. A. BOETTCHER  
FROM: I. B. MC DANIEL

884  
Station 1203 - CHARLIE

DATE 22 August 1953

Reference: Plan 6271-CH-3 Pipe Support Details.

Details for diagonal braces for Type V supports on referenced plan has notation that end support shall be 7 x 10.

The standard bracing is 8 x 8 and when material was shipped the above notation was probably not noted. There are no 6 x 10 in lengths required on this stoll. I have authorized using 8 x 8. If this is not satisfactory, these supports can be replaced if and when 6 x 10 are received.

Request approval of action taken and advise if supports should be replaced with sizes as specified.

IBM/mch

signed: I. B. McDaniel  
Asst. Resident Engineer

cc Meil Turner  
C. Burnett  
T. B. Tait  
Evan Shields  
File

COPY

COPY

COPY

*[Faint, illegible text, possibly bleed-through from the reverse side of the page]*