

SF10
RR UWFJA

DE UHPJ 19
T LA254

R 182117Z

D 10

AEC GRNC

~~SECURITY INFORMATION~~
RESTRICTED

PRESIDENT	
EXEC VICE PRES	
V.P.-S & GEN MGR	
CH FISCAL OFFCR	
ASST GEN MGR	✓
OPER CONST	✓
INDUS RELATIONS	
PROCUREMENT	
ESTIMATING	
OFFICE MANAGER	
DIR OF FINANC.	
CH DESIGN ENGR	
CH PROD. ENG.	✓
PRODUCTION	✓
SALES DIVISION	
MARKETING	
SENIOR ENGR	

TO HOW NAN LOSA

~~RESTRICTED~~

CITE ENMSG THREE TWO SIX SIX

DAVE NARVER JR FROM BOETTCHER PD REQUEST CONFIRMATION THICKNESS FIRST

FLOOR WALL SHOWN RIGHT HAND SIDE SECT ON DOG DRAWING SIX THREE TWO
FIVE SHOULD BE SIX FEET CMM ALSO THAT SAME RENFORCING APPLIES PD
REQUEST PERMISSION TO SUBSTITUTE MONOLITHIC SKONSTRUCTUION FOR
KEYED COLD JOINT BETWEEN L'MONITI AND END WALLS FIRST FLOOR

DRAWING SIX THREE TWO THREE BY POSITION BOTH LIMONITE AND ORDINARY
CINCRETE SIMULTANEOUSLY PD FOOTING XEY MM SECTION ABLE DRAWING SIX
THREE TWO FIVE WILL BE MAINTAINED IT HARA QUESTION CONFLICT FLOOR PLANS
STATION TWO THREE ZERO ZERO BETWEEN APPROVED DRAWING SIX THREE TWO THREE
AND PRELIMINARY DRAWING SIX TWO SIX ONE

16/21372